
To:	Prospective Bidders	From:	Stantec Consulting Services South Burlington, Vermont
File:	195311266	Date:	May 24, 2017

Reference: East Montpelier CMG PARK(37) – Bid Addendum #1

NOTICE TO BIDDERS:

Regarding a question on the Bid Form that within the Contract Documents dated May 1, 2017, Page 17, a duplicate line is shown for Item 620.55 Removal of Existing Fence:

- Attached to this Addendum please find a revised page 17 that deletes this duplicate line
- Please replace page 17 of your Bid Form copy with this revised sheet

NOTICE TO BIDDERS:

Regarding a question for the notation "SC-(PR)" on the Lighting Plan/Details, the following is intended to clarify that notation:

- SC is a door safety tether (aircraft cable)
- PR typical is photocell receptacle

NOTICE TO BIDDERS:

Regarding a question as to a Pre-Bid Meeting, no meeting is scheduled

NOTICE TO BIDDERS:

Regarding the possibility of and disposal of contaminated soils, please consider the following:

- Contract Documents Appendix O, includes a VT DEC Certificate of Completion (COC) for this parcel
- As noted with this COC, all excavated material is to remain onsite
- Specific to this, there are four (4) light pole bases that will require excavation below existing grade
- Be advised that the excavation for these bases is to be completed early such that any excavated soils can be disposed of in the existing mechanics pit in the existing building

STANTEC CONSULTING SERVICES INC.

gary santy
Digitally signed by gary santy
DN: cn=gary santy, o=stantec,
ou,
email=gary.santy@stantec.com,
c=US
Date: 2017.05.24 07:17:10 -04'00'

Gary A. Santy, PE
Project Manager
Phone: (802) 864-0223
Fax: (802) 864-0165
gary.santy@stantec.com

Attachment: Contract Documents, Page 17 - Revised

c. C. Bruce Johnson – Town of East Montpelier, , Wayne Davis - VTrans

Design with community in mind

East Montpelier Park and Ride CMG PARK (37)
Bid Form

May 1, 2017

618.11 Portland Cement Concrete Sidewalk, 8 inch
SY 10 \$ _____ \$ _____

Unit Price in Words _____

619.17 Yielding Marker Posts EA 4 \$ _____ \$ _____

Unit Price in Words _____

620.55 Removal of Existing Fence
LF 75 \$ _____ \$ _____

Unit Price in Words _____

621.81 Removal and Disposal of Guide Posts
EA 2 \$ _____ \$ _____

Unit Price in Words _____

630.10 Uniformed Traffic Officers
HR 50 \$ _____ \$ _____

Unit Price in Words _____

630.15 Flaggers HR 300 \$ _____ \$ _____

Unit Price in Words _____

635.11 Mobilization/Demobilization
LS 1 \$ _____ \$ _____

Unit Price in Words _____

641.10 Traffic Control LS 1 \$ _____ \$ _____

Unit Price in Words _____

646.403 Durable 4-inch White Line, Epoxy Paint
LF 1010 \$ _____ \$ _____

Unit Price in Words _____