## TOWN OF EAST MONTPELIER, VERMONT SELECTBOARD

Amy Willis (2017 – 2020) Gene Troia (2018 – 2020) Kim Swasey (2017 – 2019) Carl Etnier (2016 – 2019)

EMAIL: eastmontadmin@comcast.net PHONE: (802) 223-3313 X 204

(802) 223-4467

FAX:

Chair, Seth Gardner (2018 - 2021)

June 19, 2018

Kurt Pearson Susan Gabor 37 Gold Brook Road Stowe, VT 05672

Re: East Montpelier Access Permit #18-019

Dear Mr. Pearson & Ms. Gabor:

The East Montpelier Selectboard met on Monday, June 18, 2018, and approved the requested shift in location for the residential curb cut serving 513 Bliss Road. Please understand that parcels are limited to one curb cut absent special approval from the Selectboard. As part of the shift in access point, you will need to eliminate the existing curb cut. If you have questions on the expectations underlying this approval, please contact Road Foreman Guthrie Perry at (802) 223-5870.

Sincerely,

C. Bruce Johnson

East Montpelier Town & Zoning Administrator

Permit # 18-019	ACCESS (CURB CUT) APPLICATION	Date Received: 6/4/18	
	TOWN OF EAST MONTPELIER	Parcel #5-065.00	
Fee \$ 35.00	PO Box 157, East Montpelier, VT 05651	Tax Map # 11-00-02.000	
*************************			
Applicant: Kud Reason and Sue Yestern Phone: 002341 9618			
2.2 22 22 22	DU BROWLED GODOF STOUL	7 05672	
Property Owner: Kny Placed Sister Gabot Phone: 802 577 96)8			
Mailing Address: 37 Gold Brook Rd Sour 47 05672			
Property Location: 573 5165 (a) Flow Montguist VI (565)			
PROJECT DESCRIPTION: sketch drawing and location map must be attached.			
☐CONSTRUCT A NEW ACCESS ☐CHANGE AN EXISTING ACCESS			
	Current Access:	Proposed Access:	
agricultural commercial	☐ agricultural ☐ commercial	☐agricultural ☐commercial	
industrial	industrial	industrial	
residential	residential	residential	
development	development	development	
other	other	*	
Distance, in feet, of the propos	sed access to the nearest intersection (specify the	intersection): North of Green	
Rd. 300 - Proposed New Access Marked with Grade Stakes & Guthine did site Visit.			
Has the proposed access been flagged (i.e., marked) at the site?   YES   NO			
Site must be flagged before the application will be considered.			
The undersigned agree(s) to construct and maintain this access in accordance with applicable regulations and adhere to the specifications, restrictions, and conditions contained in this permit, if issued.			
Susan Cabor Knot Relation June 4, 2018  Applicant Date			
Applicant Date /			
Solum Ku	up Hur June 4,2	-018	
Property Owner	Date	<del></del>	
*********	***************	**********	
Denied:		#	
Approval to Proceed: Upon receipt of this permit you are authorized to proceed with the project in accordance with the conditions, specifications and restrictions, including Road Foreman recommendations, contained in this document and any attachments to this document. Approval is granted only for the work described in this application and must be performed as directed. The Permit Holder shall be responsible for all damages to persons and/or property due to or resulting from any work allowed under this permit. The Permit Holder shall defend, indemnify and hold harmless the Town of East Montpelier and its officers, agents and employees from all suits, actions or claims of any character, name and description brought on account of any injuries or damages sustained by any person or property, including all costs or expenses to defend against such suits, actions or claims.			
Date  Date  SELECTBOARD	Selectboard  SELECTBOARD	SELECTBOARD SELECTBOARD	

East Montpelier Access (Curb Cut) Application	Permit # 18-019
Road Foreman Determination:	
Proposed access meets applicable sight distance standards. Comment	ts:
Road Foreman Recommendations:  I met with one of the contractors	s and made plans the
I met with one of the contractors meet our standards.	
e <sup>1</sup>	
Culvert/Drainage Requirements:	
Roadway Culverts – 18" minimum diameter of metal, reinforced concret catch basins as required. Hydraulic Analysis to determine appropriate pip stream crossings and elsewhere where large storm follows may be expect	pe diameter is recommended for all live
Driveway Culverts – Circular drainage culverts shall have a minimum in provided by a 15" circular pipe. See VTrans Standard B-71.	side cross-sectional area equivalent to that
Underdrains - 6" minimum diameter of metal, PVC plastic or polyethyle	ene pipe.
	17/14
Road Foreman	Date
Additional Selectboard Conditions &/or Restrictions:	
The East Montpelier Land Use & Development Regulations and the	East Montpelier Road & Bridge
Standards are incorporated by reference.	

## Pearson -- 513 Bliss Road

