

ADDENDUM #2

Project: **Sander's Circle Open Bottom Arch Culvert**

Date: August 30, 2024

1. Following are questions received during the bid period and their respective answers:
 - a. Q: Is using 8.5' of overburden in the footing design acceptable?

A: The project geotechnical engineer, Sanborn Head and Associates, takes no exception to using 8.5 feet of overburden in the foundation design. As an additional clarification of the foundation design parameters in the project geotechnical report, the 2.8 ksf bearing capacity is a net allowable bearing capacity.

By:

Jennifer Devine, Town of East Montpelier Town Administrator